



**Jamaica Public Service Company
Limited**

Request for Proposals

**FRAME 5 UNIT COMBUSTION INSPECTION
SERVICES
ON THE BOGUE POWER STATION**

RFP# 882446

QUESTIONS AND ANSWERS

Suppliers are reminded to indicate their

- 1) Intention to bid in order to get access to JPS Sharefile folder; OR
- 2) Reason that they decline to bid.

Questions and Answers

1) Question:

1.1 Introduction

Please advise if the estimated outage date of September 13 is flexible. If so, please provide the outage windows that JPS could consider.

The outage date for this inspection is slated for September 13, 2021. If there is a change in this date, prior notice will be provided to contractor.

2) Question:

Appendix III – GT3 Combustion Inspection Inspection

a. Inspection and servicing of the Accessory Gear Box (via inspection port)

Please confirm the scope that is required, as it is requesting “servicing” (i.e., maintenance) of the accessory gear box, yet it indicates that this should be done “*via inspection port*”. This latter part infers that only a visual inspection is required [see item (I) for the load gear box visual inspection for reference].

Scope for accessory gearbox is visual inspection via Inspection hatch/port.

b. Perform visual inspection on Accessory Coupling.

This activity would require the removal of the accessory coupling guard. Please confirm if this is what JPS is intending. *Yes, in this the intention of JPS*

3) Question:

We have the following questions regarding the SOW for the Frame 5 CI at Bogue Station in JPS.

a) # hours per shifts

Twelve (12) hours

b) # shifts per day

Provide options in proposal for completion within timeline specified.

c) # days per week

Seven (7) calendar days

d) Could you please provide the latest Inspection report or Borescope Inspection Report.

Latest Borescope Inspection report will be provided to successful bidder.

e) When is the Outage expected to take place?

This outage is slated to commence on September 13, 2021.

END OF DOCUMENT