



**JAMAICA PUBLIC SERVICE COMPANY
LIMITED**

ADDENDUM # 2

**NEW SPUR TREE SUBSTATION DISTRIBUTION
TRANSFORMER PROJECT**

RFP# 893146

**SUPPLY 24KV AIR-INSULATED SWITCHGEAR
WITH VACUUM CIRCUIT BREAKERS**

October 2021

Issued by: Purchasing and Customs

Question and Answers.

- 1- The system characteristics shows 150kV BIL. The 27kV switchgear is 125kV, to get 150kV BIL we need to quote 38kV design. Is this acceptable?

JPS Response: **125 KV BIL is Acceptable.**

- 2- Please confirm the KV BIL rating of the switchgear. The standard rating for 27 KV indoor switchgear is 125 KV BIL, however, JPS prefers 150 KV BIL on outdoor equipment. Please keep in mind if JPS wants 150 KV BIL then the requested option with the primary switch will not work since the highest amp rating at 150 KV BIL would be 800 amps. If 800 amps is OK with JPS then this option can be quoted. Please advise.

JPS Response: **125 KV BIL is Acceptable.**

Addendum

- IB.20.1 Bids must be received by the Purchaser at the address specified under paragraph IB.19.1 no later than 11:59 pm Eastern Standard Time on **Thursday, November 25, 2021.**

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	October 5, 2021	JPS
Bidder submits questions on RFP	October 14, 2021	Bidder
Final date to respond to all queries	October 25, 2021	JPS
Bidder provide their intension to Bid	November 17, 2021	Bidder

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
Completion of RFP and deadline for submission of bids to JPS	November 25, 2021	Bidder
Bid Opening	November 26, 2021	JPS

IB.23 OPENING OF BIDS BY PURCHASER

IB.23.1 The Purchaser will open bids privately, **November 26, 2021** at:

Jamaica Public Service Company Limited,

113 Washington Boulevard

Kingston 20, Jamaica